

SPRAYING OPERATIONS

- ☐ Is adequate ventilation assured before spray operations are started?

Action to be Taken

Assigned To:

- ☐ Is mechanical ventilation provided when spraying operations are done in enclosed area?

Action to be Taken

Assigned To:

- ☐ When mechanical ventilation is provided during spraying operations, is it so arranged that it will not circulate the contaminated air?

Action to be Taken

Assigned To:

- ☐ Is the spray area free of hot surfaces?

Action to be Taken

Assigned To:

- ☐ Is the spray area at least 20 feet from flames, sparks, operating electrical motors and other ignition sources?

Action to be Taken

Assigned To:

- ☐ Are portable lamps used to illuminate spray areas suitable for use in a hazardous location?

Action to be Taken

Assigned To:

- ☐ Is approved respiratory equipment provided and used when appropriate during spraying operations?

Action to be Taken

Assigned To:

- ☐ Are solvents, detergents, or cleaner intended for that purpose?

Action to be Taken

Assigned To:

- ☐ Are fire control sprinkler heads kept clean?

Action to be Taken

Assigned To:

Spraying Operations

- ☐ Are "NO SMOKING" signs posted in spray areas, paint rooms, paint booths, and paint storage areas?

Action to be Taken

Assigned To:

- ☐ Is the spray area kept clean of combustible residue?

Action to be Taken

Assigned To:

- ☐ Are spray booths constructed of metal, masonry, or other substantial noncombustible material?

Action to be Taken

Assigned To:

- ☐ Are spray booth floors and baffles noncombustible and easily cleaned?

Action to be Taken

Assigned To:

- ☐ Is infrared drying apparatus kept out of the spray area during spraying operations?

Action to be Taken

Assigned To:

- ☐ Is the spray booth completely ventilated before using the drying apparatus?

Action to be Taken

Assigned To:

- ☐ Is the electric drying apparatus properly grounded?

Action to be Taken

Assigned To:

- ☐ Are lighting fixtures for spray booths located outside of the booth and the interior lighted through sealed clear panels?

Action to be Taken

Assigned To:

- ☐ Are the electric motors for exhaust fans placed outside booths or ducts?

Action to be Taken

Assigned To:

Spraying Operations

☐ Are belts and pulleys inside the booth fully enclosed?

Action to be Taken

Assigned To:

☐ Do ducts have access doors to allow cleaning?

Action to be Taken

Assigned To:

☐ Do all drying spaces have adequate ventilation?

Action to be Taken

Assigned To:
